



IEC TS 62782:2016

Photovoltaic (PV) modules - Cyclic (dynamic) mechanical load testing
Confirmation of Test Results

Ref.: 10018/2020-40217

Applicant: REC Solar Pte Ltd
20, Tuas South Avenue 14, 637312 Singapore

Product: Crystalline Silicon Photovoltaic (PV)-Modules

Type:

A) RECxxxPE	REC Peak Energy Series
A) RECxxxPE2SM 50	REC Peak Energy 2S Mono 50 Series
B) RECxxxPE 72	REC Peak Energy 72 Series
C) RECxxxTP	REC TwinPeak Series
C) RECxxxTP2	REC TwinPeak 2 Series
C) RECxxxTP2M	REC TwinPeak 2 Mono Series
C) RECxxxTP3M	REC TwinPeak 3 Mono Series
D) RECxxxPE 72 XV	REC Peak Energy 72 XV Series
E) RECxxxTP 72	REC TwinPeak 72 Series
E) RECxxxTP2S 72	REC TwinPeak 2S 72 Series
E) RECxxxTP2SM 72	REC TwinPeak 2S Mono 72 Series
E) RECxxxNP 72	REC N-Peak 72 Series
E) RECxxxTP3SM 72	REC TwinPeak 3S Mono 72 Serie
F) RECxxxTP 72 XV	REC TwinPeak 72 XV Series
F) RECxxxTP2S 72 XV	REC TwinPeak 2S 72 XV Series
F) RECxxxTP2SM 72 XV	REC TwinPeak 2S Mono 72 XV Series
F) RECxxxTP2SB 72 XV	REC TwinPeak 2S 72 XV Bifacial Series
F) RECxxxNP 72 XV	REC N-Peak 72 XV Series
F) RECxxxTP3SM 72 XV	REC TwinPeak 3S Mono 72 XV Series
G) RECxxxNP	REC N-Peak Series
H) RECxxxAA	REC Alpha Series
I) RECxxxAA 72	REC Alpha 72 Series
J) RECxxxAA 72 XV	REC Alpha 72 XV Series

xxx in the type number replaces the power in Watt at STC and can be any number between:
205 – 295 for A), 285 – 370 for B) & D), 260 – 335 for C), 310 – 400 for E) & F), 295 – 330 for G),
340 – 380 for H), 420 – 445 for I) & J).

Optional the type can also include at the end any of the following suffixes, or a combination of these:
ECO, BLK, BLK2, IQ, Black



Manufacturer: REC Solar Pte Ltd

Standard: IEC TS 62782:2016

Test conditions

Mechanical load cycles : 1000

Maximum pressure : ± 1000 Pa

Module Temperature : 25 °C (± 2 °C)

Pass criteria

Power degradation : < 5 %

Summary of test results:

Maximum power degradation: Allowed : max. 5 %
Measured : max. 2.11 %

The measured degradation is below the allowed degradation.

Visual inspection: No major findings

The complete test results and the relevant bill of materials are given in Test Report No.: TRPVM-2018-40288-1, TRPVM-2019-40485-1 and TRPVM-2020-40217-1

VDE Renewables GmbH

Akio Sato

Arnd Roth

63755 Alzenau, 2020-06-22

